

Coastal Distribution System water quality based on weighted quarterly averages of system sources between July 1st 2016 and March 31st 2018.

	System Production (AF)	System Average of Chloride (mg/L)	System Average of Nitrate as NO3-N (mg/L)	System Average of SAR (Sodium Adsorption Ratio)	System Average of Sodium (mg/L)	System Average of Specific Conductance (E.C.) (millimhos/cm)	System Average of Total Diss. Solids (mg/L)
Third Quarter 2016	1,606	103	5	2.63	95	1.05	625
Fourth Quarter 2016	471	124	5	2.60	94	1.15	644
First Quarter 2017	212	75	2	1.81	68	0.91	519
Second Quarter 2017 ¹	1,399	98	5	2.42	91	1.02	606
Third Quarter 2017	1,663	106	8	2.93	114	1.03	602
Fourth Quarter 2017	988	115	6	2.50	94	1.10	618
First Quarter 2018 ²	460	128	5	3.04	113	1.20	671

All samples are analyzed by an Environmental Laboratory Accreditation Program (ELAP) certified lab.

¹Second Quarter 2017 values for system production, SAR, and TDS were amended in October 2017 after a SCADA reporting issue was identified.

²First Quarter 2018 source production values are preliminary. All First Quarter 2018 values are subject to revision.