



**NOTES:**

1. TURNOUT RISER LINING AND COATING SYSTEM NO. 29 PER SPECIFICATION SECTION 09900, PAINTING & PROTECTIVE COATINGS.
2. FOR ELEVATION AND STATION SEE PLAN AND PROFILE DWGS.
3. SEE (15754) FOR ADDITIONAL INFORMATION.
4. PROVIDE SST PIPE AND NIPPLES FOR CONNECTION TO PRESSURE GAUGES AND AIR RELEASE VALVES.
5. BOND ALL BURIED JOINTS PER SPECIFICATIONS, EXCEPT HDPE, WELDED JOINTS OR THOSE WHERE INSULATING JOINTS ARE REQUIRED.
6. INSTALL (15639) AT ALL BURIED BOLTED CONNECTIONS.
7. BACKFILL AROUND VERTICAL RISER PIPE WITH PIPE ZONE MATERIAL UNLESS OTHERWISE SHOWN OR SPECIFIED.
8. PROVIDE A TEE WITH TURNOUT SIZE BY 4" BRANCH WITH BLIND FLANGE AND ROTATE TEE HORIZONTAL.
9. PROVIDE COPPER TUBING AND FITTINGS TO MAKE CONNECTION FROM THE PRV TO THE ORIFICE PLATE.
10. INSTALL SIGN (15403) ON EXISTING TURNOUTS.
11. TYPICAL WIDTH OF TURNOUT PE IS 15 FT., 7.5 FT. ON EACH SIDE OF TURNOUT PIPELINE CENTERLINE.

**TYPE 1 TURNOUT**  
NTS

**15751**